



## BLACK SERIES SMPS 60W SINGLE OUTPUT



**DIN Rail Mounting**



**Base Mounting**

All dimensions in mm

<b>FEATURES</b>	<ul style="list-style-type: none"> <li>• Single Phase Input</li> <li>• Built In Transient protector &amp; EMI filter</li> <li>• Protection against short circuit, overload &amp; overvoltage</li> <li>• Low ripple &amp; noise</li> <li>• Cooling by free air convection</li> </ul>	<ul style="list-style-type: none"> <li>• Power Ok Indication, Terminations, Output Set control &amp; Rating details on Front</li> <li>• 100% Full Load Burn in Tested</li> <li>• Low Cost</li> <li>• High Reliability</li> <li>• Compact</li> </ul>				
<b>ISOLATION</b>	Input – Output : 1.5KVAC, 1 minute Input – Earth : 1.5KVAC, 1 minute Output – Earth : 0.5KVAC, 1 minute					
<b>EFFICIENCY</b>	70 ~ 75%					
<b>O/P VOLTAGE ADJUSTMENT</b>	+/- 10% of Nominal Output Voltage					
<b>LINE &amp; LOAD REGULATION</b>	Better than 0.5%					
<b>OVERLOAD PROTECTION</b>	Yes					
<b>HOLD UP TIME</b>	> 20ms at Rated Input Voltage and Load					
<b>OPERATING AMBIENT</b>	0 ~ 50°C, 95% RH					
<b>STORAGE AMBIENT</b>	-20°C to 85°C					
<b>TERMINATIONS</b>	45 Deg. Screw type, for 2.5mm sq. wire					
<b>MOUNTING</b>	35 mm DIN rail & Screw Mounting					
<b>WEIGHT</b>	480 grams					
<b>ORDERING INFORMATION</b>	<b>NOMINAL INPUT : 230VAC/DC</b>		<b>OUTPUT</b>	<b>RIPPLE &amp; NOISE</b>	<b>OVERVOLTAGE PROTECTION</b>	
	<b>INPUT VOLTAGE</b>	<b>AC</b>				<b>DC</b>
	<b>INPUT RANGE</b>	185 ~ 270V				200 ~ 360V
	<b>IP FREQUENCY</b>	47 ~ 63Hz				—
	<b>IP CURRENT (max)</b>	1.0A @230V				0..35A @230V
	<b>INRUSH CURRENT</b>	32A @230V				23A @230V
	<b>ORDER CODE</b>	BL1250		12V : 5A	< 120mV	< 16V
<b>ORDER CODE</b>	BL2425		24V : 2.5A	< 240mV	< 30V	

**Note :**

1. All parameters measured at nominal input, rated load and 25°C of ambient temperature unless otherwise specified.
2. Ripple & noise are measured at 20MHz of bandwidth by using a 12" twisted pair-wire terminated with a 0.1uf & 100uf parallel capacitor.
3. The power supply is intended to be installed as a component inside the enclosure of final equipment. The final equipment must be re-confirmed that it still meets the EMC directives.